



Pace Analytical Services, LLC-Fairfield

1275 Bloomfield Avenue, Fairfield, NJ 07004 (973) 227-0422



ANALYTICAL RESULTS

STANDARD DELIVERABLES FORMAT

WORK ORDER NUMBER: 24J0062

DeRon School - Union

Project: Deron School - Union

Sudip Pradhan
Laboratory Director

All Results meet the requirements of the National Environmental Laboratory Accreditation Conference and/or State specific certifications as applicable.

Report Date: Oct 15, 2024



Pace Analytical Services, LLC-Fairfield

Client: DeRon School - Union
1140 Commerce Ave
Union, NJ 07083

Order ID Number: 24J0062
Received: 10/01/2024 10:00

Project: Deron School - Union
Report Date: 10/15/2024 13:13

Contact:
Customer Service Rep: Tony Tudda

Analytical Results Summary

Sample Number	Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units	Reg Limit
24J0062-01	Drinking Water		Room 100							Collected : 09/30/2024 6:45
Total Metals										
	Copper	EPA 200.8	10/14/24 15:32	10/14/24 15:32	0.266			0.00600	mg/L	
	Lead	EPA 200.8	10/14/24 15:32	10/14/24 15:32	<0.00200	U		0.00200	mg/L	
24J0062-02	Drinking Water		Main Office Pantry							Collected : 09/30/2024 6:45
Total Metals										
	Copper	EPA 200.8	10/15/24 9:49	10/15/24 9:49	0.126			0.00600	mg/L	
	Lead	EPA 200.8	10/15/24 9:49	10/15/24 9:49	<0.00200	U		0.00200	mg/L	
24J0062-03	Drinking Water		Water Fountain Main Hall							Collected : 09/30/2024 6:45
Total Metals										
	Copper	EPA 200.8	10/15/24 9:53	10/15/24 9:53	0.239			0.00600	mg/L	
	Lead	EPA 200.8	10/15/24 9:53	10/15/24 9:53	<0.00200	U		0.00200	mg/L	
24J0062-04	Drinking Water		Art Room							Collected : 09/30/2024 6:47
Total Metals										
	Copper	EPA 200.8	10/14/24 18:08	10/14/24 18:08	0.231			0.00600	mg/L	
	Lead	EPA 200.8	10/14/24 18:08	10/14/24 18:08	<0.00200	U		0.00200	mg/L	
24J0062-05	Drinking Water		Staff Room							Collected : 09/30/2024 6:48
Total Metals										
	Copper	EPA 200.8	10/14/24 18:12	10/14/24 18:12	0.236			0.00600	mg/L	
	Lead	EPA 200.8	10/14/24 18:12	10/14/24 18:12	<0.00200	U		0.00200	mg/L	
24J0062-06	Drinking Water		Kitchen Main Sink							Collected : 09/30/2024 6:49
Total Metals										
	Copper	EPA 200.8	10/14/24 18:16	10/14/24 18:16	0.187			0.00600	mg/L	
	Lead	EPA 200.8	10/14/24 18:16	10/14/24 18:16	<0.00200	U		0.00200	mg/L	
24J0062-07	Drinking Water		Water Fountain - Gym Outside High							Collected : 09/30/2024 6:50
Total Metals										

Report Date: Oct 15, 2024

See FootNotes on Last Page of Sample Results



Pace Analytical Services, LLC-Fairfield

Client: DeRon School - Union
1140 Commerce Ave
Union, NJ 07083

Order ID Number: 24J0062
Received: 10/01/2024 10:00

Project: Deron School - Union
Report Date: 10/15/2024 13:13

Contact:
Customer Service Rep: Tony Tudda

Analytical Results Summary

Sample Number	Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units	Reg Limit
24J0062-07	Drinking Water		Water Fountain - Gym Outside High						Collected : 09/30/2024 6:50	
Total Metals										
	Copper	EPA 200.8	10/14/24 18:20	10/14/24 18:20	0.210			0.00600	mg/L	
	Lead	EPA 200.8	10/14/24 18:20	10/14/24 18:20	<0.00200	U		0.00200	mg/L	
24J0062-08	Drinking Water		Water Fountain - Gym Low						Collected : 09/30/2024 6:51	
Total Metals										
	Copper	EPA 200.8	10/14/24 18:24	10/14/24 18:24	0.196			0.00600	mg/L	
	Lead	EPA 200.8	10/14/24 18:24	10/14/24 18:24	<0.00200	U		0.00200	mg/L	
24J0062-10	Drinking Water		Gym Girls Room						Collected : 09/30/2024 6:53	
Total Metals										
	Copper	EPA 200.8	10/14/24 18:29	10/14/24 18:29	0.193			0.00600	mg/L	
	Lead	EPA 200.8	10/14/24 18:29	10/14/24 18:29	<0.00200	U		0.00200	mg/L	

X: 07010: NJ DEP

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns.
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)

Report Date: Oct 15, 2024